

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.370 and NAC 534.340

OFFICE USE ONLY  
 Log No. 35698  
 Permit No. \_\_\_\_\_  
 Basin 212



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 8384

1. OWNER Doug Hash (Miller Hunt) ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 50 N. Jones Avenue #203 N/A  
Las Vegas Nev. 89107  
 2. LOCATION SW 1/4 NW 1/4 Sec. 6 T. 21S N/S R. 59 E. Clark County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  
 Other \_\_\_\_\_

6. LITHOLOGIC LAB

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
Conglomerate		3	8	
Sand Stone		8	30	
Black Clay		30	40	
Grey Clay & Water	x	40	45	
Dard Grey Sandstone		45	95	
Reddish Clay		95	140	
Clay & Water	x	140	145	
Cemented Gravel		145	195	
Reddish Shale & Water	x	195	205	
Shale		205	240	
Shale & Water	x	240	260	
Shale		260	280	
Shale & Water	x	280	300	
Sandstone Hard		300	320	
Shale & Water	x	320	340	
Shale		340	400	

Approx 150 to 200 GPM

8. WELL CONSTRUCTION  
 Total Depth 400 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 100 Feet  
9 7/8 Inches 100 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+1	400

 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

RECEIVED  
 NOV 06 1991  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 178 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 7115 Rogers St. Contractor  
Las Vegas, Nevada 89118



Date started October 17, 1991  
 Date completed October 22, 1991

Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada contractor's driller's number issued by the Division of Water Resources 552  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552  
 Signed Vernon H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date October 30, 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	