WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 35756
Permit No.
Basin 212

NOTICE OF INTENT NO. 2925

1. OWNER C & L Development/Ken Dixon
MAILING ADDRESS 4335 Industrial Rd. Ste 410
Las Vegas, NV. 89103

ADDRESS AT WELL LOCATION Ford & Industrial

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 22 N/S R. 61 E. Clark County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt & gravel		0	40	40
silt, sand & gravel		40	58	18
cemented conglomerate		58	65	7
sand & gravel		65	110	45
cemented conglomerate		110	117	7
sand & gravel		117	188	71
cemented conglomerate		188	248	60
fractured red sandstone		248	254	6
sand & gravel	*	254	260	6
fractured grey limestone		260	282	22
cemented conglomerate		282	332	50
partially cemented sand & gravel		332	395	63

RECEIVED
OCT 14 1991
Div. of Water Resources
Branch Office Las Vegas, NV.

Date started 10-8, 1991
Date completed 10-9, 1991

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	?	2

8. WELL CONSTRUCTION
Depth Drilled 395 Feet Depth Cased 395 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	395 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	395

Perforations:
Type perforation Torch
Size perforation 1/16x6x4 around
From 250 feet to 395 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 230 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling, Inc.
Contractor
Address 4847 So. Valley View Blvd.
Contractor
Las Vegas, Nv. 89103

Nevada contractor's license number issued by the State Contractor's Board 0018916/0018917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald L Walk
By driller performing actual drilling on site or contractor

Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627