



1480

PRINT OR TYPE ONLY

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. **6147**

1. OWNER **AL BELZONI** ADDRESS AT WELL LOCATION **DIAMOND AVE SANDY VALLEY NEV**  
 MAILING ADDRESS **HCR 31 Box 705 JEAN, NEV. 89019**

2. LOCATION **NW 1/4 NE 1/4 Sec 22 T 2A N18 S 56 E CLARK** County  
 PERMIT NO. **580-160-044-92**

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY Top Soil		0	3	3
CALICHE		3	11	8
CEMENTED ROCK		11	42	31
CONS BRN CLAY		42	92	50
SOFT CLAY BRN		92	108	16
GRAVEL & ROCK	WTR	108	110	2
BRN CLAY		110	123	13
CONS CLAY BRN		123	134	11
CONS WHITE CLAY		134	139	5
HARD SANDY CLAY		139	158	19
ROCK & GRAVEL	WTR	158	165	7

8. WELL CONSTRUCTION

Diameter **14** inches Total depth **165** feet

Casing record **STEEL**

Weight per foot **18** Thickness **188**

Diameter	From	To
<b>8</b> inches	0 feet	<b>165</b> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type **CEMENT**

Depth of seal **50** feet

Gravel packed: Yes  No

Gravel packed from **80** feet to **165** feet

Perforations:  
 Type perforation **FLAME CUT**  
 Size perforation **7/16 X 4"**

From **140** feet to **165** feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED

AUG 14 1991

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started **July 26**, 19**91**  
 Date completed **Aug 10**, 19**91**

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. **20** Draw down **50** feet **1** hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL

Static water level **91** feet below land surface

Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature **68** °F Quality **Good**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **RCCB INC.** Contractor

Address **1701 W. CHESTNUT LAS VEGAS 89102** Contractor

Nevada contractor's license number issued by the State Contractor's Board **020301**

Nevada contractor's driller's number issued by the Division of Water Resources **1352**

Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1352**

Signed **Robert Spaulbeck** By driller performing actual drilling on site or contractor

Date **Aug 12 91**