WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35793
Permit No.
Basin 10-137B

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11361

1. OWNER Round Mountain Gold Corp
MAILING ADDRESS P.O. Box 480
Round Mountain Nv 89045
ADDRESS AT WELL LOCATION Mine Site

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 10 N/S R. 44 E. Nye County
PERMIT NO. 44297 (Issued by Water Resources) BLM Land ? (Parcel No.) NONE (Subdivision Name)

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☒ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Reason for plugging: Water Table below bottom of well				
Plug And Abandon Well				
Pump from bottom of hole (305') To surface 15 yds. Neat cement.				
315 sks cement, 1890 gal. H_2O				
wt of cement 15.2 PPG.				
Csg was not Ripped because it has 20 slots per foot already cut from 60' To 300'				
This well was constructed To de-water open pit operations. The Pit at This time is 850' below ground Level.				

'91 FEB 26 A10:30
STATE ENGINEER'S OFFICE

Date started 2-22, 1991
Date completed 2-22, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 17½ inches Total depth 300 feet
15 inches
inches
Casing record 16" X .250 10" X .250
Weight per foot 42.05 28.04 Thickness .250

Diameter	From	To
16 inches	0 feet	20 feet
10 inches	+2 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from — feet to — feet

Perforations:
Type perforation Milled
Size perforation ⅛" X 3"
From 60 feet to 300 feet
From — feet to — feet
From — feet to — feet
From — feet to — feet
From — feet to — feet

9. WATER LEVEL
Static water level Below bottom of Well feet below land surface
Flow 0 G.P.M. 0 P.S.I.
Water temperature ? °F Quality ?
No water quality test data obtained

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co. (Contractor)
Address 2220 Stowe Dr Reno Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 24521
Nevada contractor's driller's number issued by the Division of Water Resources 1374
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1442
Signed Les Woytek
By driller performing actual drilling on site or contractor
Date 2-25-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627