WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 35845
Permit No.
Basin 101

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13621

1. OWNER BERNARD PONTE
MAILING ADDRESS 943 WEST WILLIAMS AVE.
FALLON, NEVADA 89406

ADDRESS AT WELL LOCATION 1250 RICE ROAD
FALLON, NEVADA

2. LOCATION SE ¼ NE ¼ Sec. 24 T. 19 N/S R. 28 E. CHURCHILL County
PERMIT NO. 49833, 49834 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☒ Quasi Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ + Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY & SAND (BAD WATER)		0	150	150
SET 200' OF 16" CONDUCTOR				
SANITARY SEAL				
SAND		0	6	6
BROWN CLAY		6	8	2
SAND		8	10	2
BROWN CLAY		10	15	5
SAND		15	20	5
SANDY BLUE CLAY		20	40	20
COARSE SAND		40	52	12
BLACK CLAY		52	54	2
BLK SAND W/BLK CLAY STRINGERS		54	79	25
PEA GRAVEL		79	80	1
COARSE SAND		80	95	5
HARD BROWN CLAY		95	100	5
TIGHT COARSE SAND		100	140	40
BLACK CLAY W/SAND STRINGERS		140	165	25
TIGHT SAND		165	180	15
BLACK CLAY W/S SAND		180	203	23
GREEN CLAY W/S SMALL GRAVEL		203	215	12
BROWN CLAY-COARSE SAND		215	220	5
HARD SANDY BLUE CLAY				
W/S GRAVEL	X	220	310	90
HARD BROWN CLAY & SAND		310	330	20

Date started JANUARY 15, 19 91
Date completed FEBRUARY 7, 19 91

'91 MAR -6 AM 10:06

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	107	206	47

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12 inches Total depth 330 feet
20 inches from 0 to 200
12 inches from 200 to 330
Casing record 16" & 12"
Weight per foot ..... Thickness .250

Diameter	From	To
16" BLANK inches	0 feet	200 feet
12" BLANK inches	0 feet	275 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 200 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TRIPLE ROW
Size perforation 12"
From 275 feet to 330 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 31.5 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address P.O. Box 592 Wmca., NV 89445
Contractor
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada contractor's driller's number issued by the Division of Water Resources 1154
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 795
Signed [signature]
By driller performing actual drilling on site or contractor
Date 3-4-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627