WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 35854
Permit No.
Basin 76

NOTICE OF INTENT NO. 14677

1. OWNER Randolph Jackson
MAILING ADDRESS 4470 Daywalt
Sebastapol, Ca 95472

ADDRESS AT WELL LOCATION # 5 A Inglewood
Lot 22 Block 4

2. LOCATION NE ¼ NW ¼ Sec. 13 T 20 N/S R. 24 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 20-342-14 (Parcel No.) Good Earth (Subdivision Name)

3. TYPE OF WORK
New Well XX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden brown clay		0	21	21
Cobbles & sand - black and red		21	27	6
Mixed black & red sands with soft white rock		27	52	25
Multi-colored coarse sands mixed with brown clay		52	95	43
Multi-colored fine sands & brown clay		95	97	2
Cobbles brown clay & gravels - 1/4 to 3/8"		97	141	44
T. D. is light brown clay with gravels T.D. 141 ft				
There is a 12 ft blank on bottom of screen open ended				

Date started 2/18/91, 19
Date completed 2/18/91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 141 feet
inches
inches
Casing record 6 5/8 inch
Weight per foot 12.92 Thickness .188

Diameter	From	To
6 5/8 inches	+ 1 feet	141 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type neat cement
Depth of seal 100 feet
Gravel packed: Yes XX No ☐
Gravel packed from 100 feet to 141 feet

Perforations:
Type perforation Screen - Roscoe-Moss
Size perforation .030
From 117 feet to 129 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 17 feet below land surface
Flow 20+ G.P.M. P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Aqua Drilling & Well Service, Inc (Contractor)
Address 625 Spice Islands Dr Suite L Sparks 89431 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 15291
Nevada contractor's driller's number issued by the Division of Water Resources 1132
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1132
Signed Roger M. Thrall (By driller performing actual drilling on site or contractor)
Date Roger M. Thrall 2/19/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627