WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 35965
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14814

1. OWNER Robert Clements
MAILING ADDRESS 5650 Talbot Lane
Reno, NV 89509

ADDRESS AT WELL LOCATION 5650 Talbot Lane
Reno, NV 89509

2. LOCATION ~~NW~~ NE ¼ ~~SW~~ NW ¼ Sec. 36 T ~~18N~~ 19N N/S R ~~20~~ 19E E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. 4008126 Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On 3-1-'91 we abandoned a6" domestic well that was about 60' deep with static water level 37'. Per Rob Martinez, we filled in the bottom of the well with a betonite pellets from about 30-60'. We then filled the hole to the top using neat cement slurry. The well was located within the home's boiler room. The abandonment was witnessed by Washoe Co. Health Dept. Roy DeRicco.				

91 MAR -6 AM 10:06
STATE ENGINEER

Date started 3-1- , 1991
Date completed 3-1- , 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole ..... inches Total depth 60' feet
Casing record
Weight per foot ..... Thickness

Diameter	From	To
6" inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 37' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R. Bruce MacKay, MAC KAY Pump & Geothermal (Contractor)
Address 1600 Mt. Rose Hwy. Reno, NV 89511 (Contractor)
Nevada contractor's license number 23096
Nevada contractor's drillers number M1719
Nevada driller's license number M1719 (Actual Driller)
Signed R. Bruce MacKay (Contractor)
Date 3-1-'91

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434