

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 14815

PRINT OR TYPE ONLY

1. OWNER ROBERT CLEMENTS ADDRESS AT WELL LOCATION 5650 TALBOT
 MAILING ADDRESS 5650 TALBOT
RENO, NV 89509

2. LOCATION NW SW Sec 36 T 18 N 20 E Washoe County
 PERMIT NO. NE NW 40-081-26 19N R.19E. Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other REDRILL

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| CLAY & COBBLES | | 0 | 50 | 50 |
| SAND | | 50 | 63 | 13 |
| CLAY & COBBLES | | 63 | 138 | 75 |
| CLAY & SAND LAYERS | | 138 | 146 | 8 |
| ROCK | | 146 | 160 | 14 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

8. WELL CONSTRUCTION

Diameter 6 inches Total depth 160 feet
 inches
 inches

Casing record 6 5/8 X 160
 Weight per foot 12.9 Thickness 1.88

| Diameter | From | To |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>160</u> feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation MACHINE SLOT
 Size perforation 3/32 X 3
 From 117 feet to 157 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 2-21-91, 19____
 Date completed 2-25-91, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|-------------|--------|-----------|------------------|
| | | | |
| AIR BLOWN @ | GPM | | |
| | | | |

9. WATER LEVEL
 Static water level 37 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WELSCO CORP. Contractor
 Address P. O. BOX 888 FALLON, NV 89406 Contractor
 Nevada contractor's license number 11752 issued by the State Contractor's Board
 Nevada contractor's driller's number 772 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 030191

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
| | | | |
| | | | |
| | | | |