WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36074
Permit No.
Basin

NOTICE OF INTENT NO. 13674

1. OWNER Carson City Public Works
MAILING ADDRESS 3300 Buttle Way
Carson City, Nevada 89701

ADDRESS AT WELL LOCATION
Bennett Ave
Carson City, Nevada

2. LOCATION 800 feet E ¼ Sec. 33 T. 15 N/S R. 20 E Carson City County

PERMIT NO. 56531 W- 349 (Issued by Water Resources) | NA (Parcel No.) | NA (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| ~~Sandy / DG~~ | | ~~0~~ | ~~7~~ | ~~7~~ |
| ~~Clay~~ | | ~~7~~ | ~~10~~ | ~~3~~ |
| ~~Sandy/DG/SM Gravel~~ | | ~~10~~ | ~~92~~ | ~~82~~ |
| ~~Granite / Bedrock~~ | | ~~92~~ | ~~115~~ | ~~23~~ |
| ~~Fractured Bedrock/ Granite~~ | | ~~115~~ | ~~122~~ | ~~7~~ |
| ~~Hard Granite/Bedrock~~ | | ~~122~~ | ~~125~~ | ~~3~~ |
| Abandon #45c | 7 BAG mix | | 2 yds | |
| Set 2" Tremmie Pipe | | 0 | 115 | |
| Pumping Grout | | | | |
| Pull 20' | | 115 | 95 | |
| Pumping Grout | | | | |
| Pull 20' | | 95 | 75 | |
| Pumping Grout | | | | |
| Pull 20' | | 75 | 55 | |
| Pumping Grout | | | | |
| Pull 20' | | 55 | 35 | |
| Pumping Grout | | | | |
| Pull 20' | | 35 | 15 | |
| Pumping Grout | | | | |
| Pull and grout to surface | | | | |
| Abandoning done in accordance to the rules and regulations of the State of Nevada. Official on site. | | | | |

Date started 9/30, 19 91
Date completed 9/30, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | NA | |

8. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased X Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8½ Inches | | 0 Feet | 125 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | NA | | |

Perforations:
Type perforation NA
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 125
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
7 BAG mix
Gravel Packed: [ ] Yes [ ] No
From feet to feet

9. WATER LEVEL
Static water level DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co (Contractor)
Address P.O. BOX 590 (Contractor)
Winnemucca, Nevada 89446-0590
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533
Signed C. O. Eyla (By driller performing actual drilling on site or contractor)
Date 10-11-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627