

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 17294

1. OWNER Wholey Construction ADDRESS AT WELL LOCATION 11555 Osage
MAILING ADDRESS 10190 Crockett Lot 10 Washoe Ranches
Reno, Nv 89506

2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 21 N/S R. 18 E. Washoe County
PERMIT NO. 086-232-10 - Silver Knolls
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Mud <input type="checkbox"/>
Domestic <input checked="" type="checkbox"/> Municipal <input type="checkbox"/>		

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine sand & brown clay		0	14	14
Brown clay & fine sands		14	73	59
Medium fine sand and multi-colored mostly sands with brown clay		75	165	90
Sticky brown clay with some sand		165	176	11
Medium fine sands		176	190	14
Sandy clay - medium coarse sands angular		190	218	28
T.D. 218 ft				

8. 10" - 55' WELL CONSTRUCTION

Diameter 8 3/4 inches Total depth 218 feet

Casing record 6 5/8 inch Weight per foot 12.92 Thickness .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+1 1/2</u> feet	<u>218</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes No Type neat cement

Depth of seal 50 feet

Gravel packed: Yes No Gravel packed from 50 feet to 218 feet

Perforations:

Type perforation factory

Size perforation 1/8 X 3

From 188 feet to 208 feet

From _____ feet to _____ feet

Date started 4/4/91, 19____

Date completed 4/4/91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 106 feet below land surface

Flow 20+ G.P.M. P.S.I.

Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
Contractor

Address 625 Spice Islands Dr Suite L Sparks
Contractor 89431

Nevada contractor's license number 15291
issued by the State Contractor's Board

Nevada contractor's driller's number 1132
issued by the Division of Water Resources

Nevada driller's license number issued by the 1132
Division of Water Resources, the on-site driller

Signed Roger M. Thrall
By driller performing actual drilling on site or contractor

Date Roger M. Thrall 4/5/91