WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37068
Permit No.
Basin 101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17091

1. OWNER NATHAN PUNCHARD
MAILING ADDRESS P. O. BOX 2618
FALLON, NEVADA 89406

ADDRESS AT WELL LOCATION 150 WILDATE
FALLON, NV 89406

2. LOCATION NE ¼ SW ¼ Sec. 18 T. 18 N/S R. 29 E. CHURCHILL County

PERMIT NO. NA (Issued by Water Resources) | 006-811-36 (Parcel No.) | PARCEL # 4 OF JAMES & BEVERLY FLETCHER (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SOIL		0	3	3
SAND		3	8	5
CLAY		8	16	8
FINE SAND		16	32	16
BLACK CLAY & SILT		32	65	33
GRAY CLAY & SAND		65	107	42
CLAY		107	113	6
COARSE SAND & GRVL	X	113	122	9

'91 JUN 19 A0:5
STATE ENGINEER

Date started JUNE 12, 1991
Date completed JUNE 13, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
AIR BLOWN	@ 35 GPM		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 5/8 inches Total depth 122 feet
..... inches
..... inches
Casing record 6 5/8 X .188 X 122
Weight per foot 12.9 Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	122 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation MACHINE SLOT
Size perforation 3/32X3
From 115 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow NA G.P.M. NA P.S.I.
Water temperature 61 °F Quality UNTSTD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (Contractor)
Address P. O. BOX 888 FALLON, NV 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada contractor's driller's number issued by the Division of Water Resources 772
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed ..... (By driller performing actual drilling on site or contractor)
Date 6-16-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627