WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 37136
Permit No.
Basin 061-

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16721

1. OWNER Barrick Goldstrike Mines
MAILING ADDRESS P.O. Box 29
Elko, NV 89801

ADDRESS AT WELL LOCATION
PZ-91-4

2. LOCATION NE ¼ SW ¼ Sec. 19 T 36 N/S R 50 E Eureka County
PERMIT NO. M/O-156-B
Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitor
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown broken		0	80	80
Red broken		80	240	160
Brown med.		240	275	35
Gray med.		275	360	85
Black med.		360	435	75
Black broken	x	435	460	25
Black hard		460	560	100
Black broken	x	560	600	40
Black hard		600	705	105
Black broken	x	705	720	15
Black hard		720	735	15

'91 AUG 30 AM 8:52
STATE ENGINEER

Date started 8-10- , 19 91
Date completed 8-15- , 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6¼ inches Total depth 735 feet
..... inches
..... inches
Casing record 1½" PVC
Weight per foot ..... Thickness Sch. 80

Diameter	From	To
1¼ inches	+2 feet	540 feet
1¼ inches	+2 feet	735 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 540 feet to 495 feet
735 ft. to 695 ft.

Perforations:
Type perforation Slotted 1½" PVC
Size perforation 0.10
From 500 feet to 540 feet
From 695 feet to 735 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 240 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elsing Drilling & Pump Co., Inc
Contractor
Address P.O. Box 919 Twin Falls, ID 83303
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0017177
Nevada contractor's driller's number issued by the Division of Water Resources 1295
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1728
Signed Arnold Elsing
By driller performing actual drilling on site or contractor
Date 8-28-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627