

OFFICE USE ONLY
 Log No. 3757
 Permit No. 7-920
 Basin 7-920

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19449

1. OWNER (1) ASHBE County Utility Division ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 11130
Reno Nev.
 2. LOCATION N1/4 S1/4 Sec. 22 T 21N N/S R 19E E WASHOE County
 PERMIT NO. M10-383 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Very fine sand, clay		0	22	22
brown clay		22	45	23
sand		45	75	30
Sand & clay		75	140	65
clay		140	200	60
sand, brown gravel		200	225	25
gravel		225	240	15
sand gravel		240	270	30
silty clay, silty sand		270	300	30
clay		300	350	50
clay		360	390	30
gravel, sand	X	390	450	60

8. WELL CONSTRUCTION
 Depth Drilled 460 Feet Depth Cased 450 Feet
 HOLE DIAMETER (BIT SIZE)
7 7/8 Inches From 0 Feet To 460 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 7/8"</u>	<u>3,653</u>	<u>.154</u>	<u>0</u>	<u>450</u>
<u>2" galvanized</u>				

Perforations:
 Type perforation MILL SLOT
 Size perforation _____
 From 198' feet to 450' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 80' Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 450 feet to 80' feet

9. WATER LEVEL
 Static water level 55' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BEYLIK DRILLING Contractor
 Address 3429 LONGVIEW DR. Contractor
N. HIGHLANDS CA 95060
 Nevada contractor's license number issued by the State Contractor's Board 0007055A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1660
 Signed M. Nash
 By driller performing actual drilling on site or contractor
 Date 9-3-91

Date started 8-23, 1991
 Date completed 8-30, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)