

OFFICE USE ONLY
 Log No. 37276
 Permit No. _____
 Basin 8-103



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 17150

PRINT OR TYPE ONLY

1. OWNER SAL Quilici ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2201 MARVIN DR. CARSON CITY NV. 89103 490 DAYTON VALLEY RD.
 2. LOCATION SE 1/4 NW 1/4 Sec. 18 T. 16 N. & R. 22 E. Lyon County
 PERMIT NO. NA. 16-341-02 Parcel No. _____
 Issued by Water Resources Subdivision Name NATER

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND.</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>CLAY WITH ZEPHYRUS</u>		<u>8</u>	<u>60</u>	<u>52</u>
<u>BEDDED SAND & GRAVEL</u>				
<u>FINE GRAY SAND & SILT.</u>		<u>60</u>	<u>82</u>	<u>22</u>
<u>COBBLES SAND & GRAVEL WITH ZEPHYRUS</u>		<u>82</u>	<u>180</u>	<u>98</u>
<u>BEDDED SANDY CLAY</u>				

JUL 23 10:34 AM '91
 RECEIVED
 STATE ENGINEERS OFFICE

Date started July 9, 1991
 Date completed July 18, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>120'</u>	<u>50</u>	<u>60 M</u>	<u>FROM</u>
	<u>60'</u>	<u>2 HRS.</u>	

8. BAILER TEST

G.P.M. NA. Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION

Diameter 15 inches Total depth 180 feet
 _____ inches
 _____ inches

Casing record _____
 Weight per foot 19 lb. Thickness .219

Diameter	From	To	Thickness
<u>8</u> inches	<u>+ 3</u>		<u>178</u> feet
_____ inches			_____ feet
_____ inches			_____ feet
_____ inches			_____ feet
_____ inches			_____ feet
_____ inches			_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 110 feet
 Gravel packed: Yes No
 Gravel packed from 110 feet to 180 feet

Perforations:
 Type perforation 1/8 mill cuts
 Size perforation 4 x 2 1/2
 From 138 feet to 178 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 60' TOP CASING feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 60 °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DAVIS DRILLING INC.
 Address P.O. Box 21921 CL. NV. 89121
 Nevada contractor's license number 0023129
 issued by the State Contractor's Board
 Nevada contractor's driller's number NA.
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Anz
 By driller performing actual drilling on site or contractor
 Date 7-18-91