WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37326
Permit No.
Basin 104.

NOTICE OF INTENT NO. 19489

1. OWNER KEVIN GATTIS
MAILING ADDRESS 2490 Merrit Dr
Carson City, NV

ADDRESS AT WELL LOCATION 3150 Kings Canyon Road
Carson City, NV 89703

2. LOCATION SW ¼ SW ¼ Sec. 13 T. 15 N/S R. 19 E. Carson City County
PERMIT NO. (Issued by Water Resources) 07-081-25 (Parcel No.) Kings Canyon (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden & boulders		0	5	5
Sandy clays		5	15	10
Gray clay		15	25	10
Gravels		25	30	5
Talus rock, hard		30	80	50
Gray clays		80	83	3
Gravels		83	90	7
Talus rock, hard		90	160	70
Broken sandstone with	xd	160	180	20
Broken sandstone with clay		180	200	20
Talus rock, hard, with water	xx	200	220	20
Total depth: 220 feet				
Well Capacity: 25-27	GPM from 20	feet		

Date started Aug 25, 19 91
Date completed Aug 29, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed well and gravel packed well using air compredsor. Blew 25 plus gpm for 2 hours until clean.		

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 7/8 Inches		0 Feet	100 Feet
9 1/2 Inches		100 Feet	220 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	220

Perforations:
Type perforation Factory Mill Slotted
Size perforation 3" x 3/32"
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 220 feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. 25-27 P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. (Contractor)
Address 5551 Hiway 50 E unit 3 (Contractor)
Carson City, NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date Aug 29, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627