WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37346
Permit No.
Basin 105-

NOTICE OF INTENT NO. 17454

1. OWNER Herbert W. Gray
MAILING ADDRESS 1614 Chowbuck Dr. Gardnerville, Nev. 89410
ADDRESS AT WELL LOCATION 1614 Chowbuck Dr. Gardnerville, Nev. 89410

2. LOCATION SW ¼ NW ¼ Sec. 35 T. 14N N/S R. 20E E. Douglas County
PERMIT NO. (Issued by Water Resources) 21-250-18 (Parcel No.) Johnson Ln. (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Clay, Sandy		3	27	24
Gravel		27	62	35
Gravel, Cemented		62	97	35
Clay		97	102	5
Conglomerate		102	139	37
Clay		139	145	6
Conglomerate	X	145	164	19
Clay		164	178	14
Rock, Grey/Broken	X	178	210	32

'91 OCT 18 A11:00 STATE ENGINEER'S OFFICE

Date started 8/27, 19 91
Date completed 8/29, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		2

8. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	50 Feet
8 3/4 Inches		50 Feet	210 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		0.188	0	210

Perforations:
Type perforation Factory Slotted
Size perforation 3/32 X 3"
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 210 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Pre-Cambrian Drilling Co. Inc. (Contractor)
Address 794 Foothill Rd. Gardnerville Nev/ 89410 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030267
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652
Signed (By driller performing actual drilling on site or contractor)
Date 9/20/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627