

OFFICE USE ONLY
 Log No. 37372
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19283

1. OWNER VIC WARD ADDRESS AT WELL LOCATION 2728 Gordon
 MAILING ADDRESS 2724 Gordon St. Gardnerville, NV 89410
 2. LOCATION NE 1/4 SW 1/4 Sec. 34 T. 14 N/S R. 20 E. Douglas County
 PERMIT NO. 21-170-61 Parcel No. Johnson Lane Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	3	3
Sand & clay		3	20	17
Sand & gravel		20	30	10
Sand & clay		30	55	15
clay		55	60	5
Sand & gravel	X	60	95	35
Sand & clay		95	100	5
clay		100	105	5
Sand & clay		105	115	10
Sand & gravel	X	115	140	25
clay		140	142	2
Sand & gravel	X	142	150	8

'91 JUL 24 A9:18
 STATE WELLERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 150 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 150 Feet
 Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>11</u>	<u>150</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 3/32" X 3"
 From 120 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 150 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow 0 G.P.M. 10 P.S.T.
 Water temperature Good °F Quality Good

Date started 7-19, 1991
 Date completed 7-19, 1991

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Energy Exploration Drilling Contractor
 Address PO Box 1538 Contractor
Minden, NV 89423
 Nevada contractor's license number issued by the State Contractor's Board 21491
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1407
 Signed Vic Ward
 By driller performing actual drilling on site or contractor
 Date 7-22-91