WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37576
Permit No.
Basin 71

NOTICE OF INTENT NO. 15461

1. OWNER Dale Loveridge
MAILING ADDRESS P.O. Box 606
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION 6050 Pedroli
Winnemucca, NV 89445

2. LOCATION SW ¼ SW ¼ Sec. 10 T 36 N/S R 38 E Humboldt County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 2 Subdivision Name N/A

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	6	6
Course Sand		6	10	4
Blow Sand		10	30	20
Course Sand/Trace Clay		30	34	4
Course Sand/Gravel	✓	34	65	31
Brown Sandy Clay/ Some Gravel	✓	65	98	33
Clay/Sand Gravel Stringers	✓	98	120	22

Date started Sept 18, 19 91
Date completed Sept 20, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	Air on rig	

8. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	120

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	100

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 2
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 120 feet to 50 feet

9. WATER LEVEL
Static water level 27 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co. Inc. (Contractor)
Address P.O. Bos 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1448
Signed (By driller performing actual drilling on site or contractor)
Date 9-23-91

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627