WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37604
Permit No.
Basin 6-85

NOTICE OF INTENT NO. 17763

1. OWNER Kenneth & Marsha Dupree
MAILING ADDRESS P.O. Box 46
Sparks, Nev. 89432

ADDRESS AT WELL LOCATION 95 EL. Molino Dr.
Spanish Springs, Sparks Nev. 89436

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 21 N/S R. 20 E. Washoe County
PERMIT NO. n/a Issued by Water Resources
~~D APN #1700~~ 76-580-56
Jack Morrison Subdivision Name
Parcel Dof parcel map 1700

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	100	100
Gravel		100	160	60
Basalt Cap		160	162	2
Gravel		162	190	28
Clay		190	240	50
Gravel	X	240	270	30

'91 OCT 25 A10:38
STATE ENGINEER'S OFFICE

Date started October 14, 19 91
Date completed October 18, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 270 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	60 Feet
8-3/4 Inches	60 Feet	270 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	270

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 250 feet to 270 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 270 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. Contractor
Address P.O. BOX 1265 Contractor
FALLON, NEV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696
Signed Walter Parsons By driller performing actual drilling on site or contractor
Date 10/24/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627