WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37611
Permit No.
Basin 7-02a

NOTICE OF INTENT NO. 20147

1. OWNER STACY RUMBAUGH
MAILING ADDRESS 7600 Yorkshire Dr.
Reno, NV 89506

ADDRESS AT WELL LOCATION 10695 Silver Knolls BLVD.
Reno, NV 89506

2. LOCATION SE ¼ SW ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 086-201-03 (Parcel No.) Silver Knolls (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	63	62
Soft zone (NO WAATER)		63	69	6
Brown sandy clay		69	89	20
Brown clay		89	95	6
Brown soft sand		95	101	6
Brown sandy clay		101	131	30
Soft zone, sand	X	131	149	18
Brown clay		149	153	4
Soft zone, med. coarse sand	X	153	174	21
Brown clay		174	176	2
BRown sand		176	179	3

'91 NOV 18 P1:25
STATE ENGINEER

Date started 11-12-91, 19
Date completed 11-12-91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 179 Feet Depth Cased 179 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	179 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	179

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 134 feet to 174 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 179 feet

9. WATER LEVEL
Static water level 101 feet below land surface
Artesian flow 22 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date November 14, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627