

OFFICE USE ONLY
 Log No. 37015
 Permit No. 3125
 Basin 7-92(B) Lemmon V.

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18250

1. OWNER Church of Jesus Christ of Latter-Day Saints ADDRESS AT WELL LOCATION 8080 Lemmon Drive
 MAILING ADDRESS 855 Industrial Way Sparks, Nv 89431

2. LOCATION SE 1/4 SE 1/4 Sec. 4 T. 20 N/S R. 19 E. Washoe County Washoe
 PERMIT NO. 31252 086-390-10 - Lemmon Valley Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
The 6 inch liner in this well was pulled out. The well was to be deepened - but could not keep bore hole open				
Blowing greenish D.G. chunks & fine sand				
Air lift for 3 hrs from 280 ft to clean water-up				
When drill rod & stabilizer were pulled out the bore hole was full to the bottom of original 8 inch casing				
Air lift for 1 hour to clean water from 230 ft.				
T.D. 246 ft				

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

Refer to original log

From To
 _____Inches _____Feet _____Feet
 _____Inches _____Feet _____Feet
 _____Inches _____Feet _____Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation.....
 Size perforation.....

From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal.....

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From.....feet to.....feet

9. WATER LEVEL

Static water level.....feet below land surface
 Artesian flow.....G.P.M.P.S.I.
 Water temperature.....°F Quality.....

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc
 Contractor
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board.....

Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.....

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date 12/17/91

Date started 12/16/91, 19.....
 Date completed 12/17/91, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>60</u>	<u>4</u>	<u>4</u>