WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37619
Permit No.
Basin 99

NOTICE OF INTENT NO. 18259

1. OWNER: Tom Taylor
MAILING ADDRESS: 6060 Plumas Apt E, Reno, Nv 89509
ADDRESS AT WELL LOCATION: 15600 Frontier, Red Rock

2. LOCATION: SW ¼ SW ¼ Sec. 2 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) — Parcel No. 078-241-06 — Subdivision Name: Sierra Rahchos

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
D. G.		0	14	14
Blue & green & white sands with blue green clay		14	42	28
D.G. brown & tan		42	171	129
Red rock with coarse D.G.		171	198	27
Red rock with D.G. & some brown clay		198	233	35
Fractured black rock mixed with D.G. & Red tan orange clay		233	248	15
Mix of colored clays red rock with scattered black rock		248	278	30
There is a 20' blank on bottom of perf.				
T.D. 278 ft				

Date started 10/9/91, 19
Date completed 10/10/91, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [XX] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18 - 20		2 ½

8. WELL CONSTRUCTION
Depth Drilled 278 Feet Depth Cased 278 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	60
8	60	278

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	+ 1	278

Perforations:
Type perforation: Factory
Size perforation: 3/32 X 3
From 178 feet to 198 feet
From 238 feet to 258 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [XX] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 278 feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Aqua Drilling & Well Service, Inc
Address (Contractor): 625 Spice Islands Dr Suite L, Sparks, Nv 89431
Nevada contractor's license number issued by the State Contractor's Board: 15291
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1132
Signed (by driller performing actual drilling on site or contractor): Roger M. Thrall
Date: 10/12/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627