WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 37624
Permit No.
Basin 101

NOTICE OF INTENT NO. 17548

1. OWNER Mike McGreggor
MAILING ADDRESS 17374 Donert St.
Hespenia Calif. 92345

ADDRESS AT WELL LOCATION
8767 Reno Hwy.
Fallon, Nev. 89406

2. LOCATION NE ¼ NW ¼ Sec. 30 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. 55593 (Issued by Water Resources) 0715152 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	8	8
Coarse Sand		8	12	4
Fine Brown Sand		12	17	5
Green Clay		17	28	11
Brown Sandy Clay		28	33	5
Brown Coarse Sand		33	44	11
Green Sand		44	47	3
Green & Black Coarse Sand		47	62	15
Brown Clay		62	64	2
Brown Coarse Sand		64	73	9
Green Sand		73	76	3
Gray Clayish sand		76	78	2
Black & White Coarse Sand		78	81	3
Black Sandy Clay		81	88	7
Gray Sand		88	93	5
Black & White Coarse Sand		93	96	3
Brown Clay		96	99	3
Brown Coarse Sand & Gravel	X	99	111	12

Date started Sept. 25, 19 91
Date completed Sept. 25, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 111 Feet Depth Cased 111 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	111 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-7/8	16.94	.188	0	111

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 106 feet to 110 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 111 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nev. 89406
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date Oct 10, 1991

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627