



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6171

PRINT OR TYPE ONLY

1. OWNER Shiplely Const. Co. for Raymieundo Rangel ADDRESS AT WELL LOCATION 6900 Farm Road
 MAILING ADDRESS 2724 Eagle Springs Court, Las Vegas, Nevada
Las Vegas, Nevada 89117

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 19 N/S R. 60 E. Clark County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay and gravel		0	15	15
gravel		15	25	10
white clay		25	94	69
gravel	xx	94	105	11
brown clay		105	125	20
gravel	xx	125	128	3
brown clay		128	185	57
gravel		185	190	5
brown graveley clay	xxx	190	350	160
graveley clay	xxx	350	400	50

8. WELL CONSTRUCTION

Diameter 10" inches Total depth 400 feet
 _____ inches
 _____ inches
 Casing record 8 5/8" to 400 ft.
 Weight per foot .188 wall Thickness _____
 Diameter From To
12" Hole inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
10" Hole inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
8 5/8" casing inches _____ feet _____ feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 ft. feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation torch cut
 Size perforation 3/16" X 10"
 From 105 feet to 400 feet
 From _____ feet to _____ feet

RECEIVED JUN 16 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

RECEIVED APR 5 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-27-92, 19____
 Date completed 5-21-92, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed 40 G.P.M. from 180 ft.			30 min test

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 101 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name S. R. McKinney & Sons, Inc. Contractor
 Address 1042 South Main St. Las Vegas, Nevada Contractor
 Nevada contractor's license number 2065
 issued by the State Contractor's Board
 Nevada contractor's driller's number 45
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 270
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6-9-92

