WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.240

OFFICE USE ONLY
Log No. 37653
Permit No.
Basin

NOTICE OF INTENT NO. 9401

1. OWNER Danny Lambart
MAILING ADDRESS
ADDRESS AT WELL LOCATION N/A

2. LOCATION SW ¼ NE ¼ Sec. 22 T 19S N/S R 60 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
Pop Corn Caliche		2	12	
Caliche		12	14	
Pop Corn Caliche		14	28	
Caliche		28	60	
Clay		60	75	
Caliche		75	100	
Clay & Water	x	185	210	
Clay		100	185	
Clay		210	350	
Caliche		350	360	
Clay & Water	x	360	400	
Clay		400	460	
Clay & Water	x	460	500	

RECEIVED
APR 24 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started April 11, 92, 19
Date completed April 17, 92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches	0 Feet	500 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	500

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 460 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 230
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 230 feet to 500 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 3035 S. Torrey Pines (Contractor)
Las Vegas, Nevada

Nevada contractor's license number issued by the State Contractor's Board 10062

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick
By driller performing actual drilling on site or contractor

Date April 22, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627