WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 37741
Permit No.
Basin 212

NOTICE OF INTENT NO. 3313

1. OWNER Robert Day
MAILING ADDRESS 5067 Stormy Cr.
Las Vegas, Nev. 89119

ADDRESS AT WELL LOCATION
Pyle & Giles

2. LOCATION NE ¼ SW ¼ Sec. 28 T. 22 N/S R. 61 E. Clark County

PERMIT NO. (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silt & gravel		0	18	18
calichi		18	19	1
partially cemented		19	86	67
sand & gravel clay				
sand & gravel		86	99	13
cemented conglomerate		99	119	20
red clay sand & gravel		119	179	60
cemented	185	179	195	16
gravel conglomerate		195	316	72
cemented		316	229	13
partially cemented		229	400	71

RECEIVED
APR 02 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-17, 19 92
Date completed 3-20, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	?	2

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	400

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	12.92	.188	+1	400

Perforations:
Type perforation Torch
Size perforation 1/8" x 6" x 4 around
From 200 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 146 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89103

Nevada contractor's license number issued by the State Contractor's Board 0018917

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661

Signed Donald L Walker
By driller performing actual drilling on site or contractor

Date 3-26-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627