

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18256

1. OWNER Helene Day & Mike Zglinski ADDRESS AT WELL LOCATION 3360 Cartwright
 MAILING ADDRESS 3140 W. Plumb Ln Lot 336
Reno, Nv 89509
 2. LOCATION NE 1/4 SW 1/4 Sec. 22 T 18 N/S R. 21 E Storey County Storey
 PERMIT NO. 03-361-35 - Virginia City Highland Ranches
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock & clay red		0	22	22
Greenish volcanic rock & green clay		22	42	20
Red volcanic rock		42	46	4
Green volcanic hard rock some clay		46	177	131
Hard green volcanic rock some fractures		177	273	96
T.D. 273 feet				

8. WELL CONSTRUCTION
 Depth Drilled 273 Feet Depth Cased 273 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	53
8 1/2	53	177
6 1/8	177	273

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 3	177
5	9.66	.188	173	273

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 157 feet to 177 feet
 From 233 feet to 253 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 53 Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 53 feet to 177 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller.
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date 9/16/91 Roger M. Thrall

Date started 9/13/91, 19_____
 Date completed 9/13/91, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2 hrs

91 SEP 19 AM 1:30

WELL EXPLORATION