WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38018
Permit No.
Basin 6-8a

NOTICE OF INTENT NO. 19478

1. OWNER Alford Stiller
MAILING ADDRESS 395 Lake Dr. Carson City Nv. 89704
ADDRESS AT WELL LOCATION 395 Lake Dr.

2. LOCATION NE ¼ SE ¼ Sec. 23 T. 17 N/S R. 19 E Old Washo County
PERMIT NO. Issued by Water Resources
60-220-45 Parcel No.
Old Washo City Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Sandstone (Hard)		3	15	12
Gravels		15	45	30
Course D.G.		45	65	20
Sandy Clay		65	80	15
Gravels		80	105	25
Gravels w/water	xxx	105	120	15
120' TD				

'91 NOV -5 A9:52
STATE ENGINEERS OFFICE

Date started 10 29, 1991
Date completed 11/1, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40+	20	2 Hr.

8. WELL CONSTRUCTION
Depth Drilled 120' Feet Depth Cased 120' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 1/4 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	120'

Perforations:
Type perforation Mill Slot
Size perforation 3/32 x 3 1/2
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 100 feet to 120' feet

9. WATER LEVEL
Static water level 14' feet below land surface
Artesian flow G.P.M. 40+ P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAH Pump Co. Contractor
Address 5551 Hyso East #3 Carson City Nv. Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts By driller performing actual drilling on site or contractor
Date 11/1/91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627