

OFFICE USE ONLY  
 Log No. 38020  
 Permit No. 6-89  
 Basin I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17453

1. OWNER Jim Bushman ADDRESS AT WELL LOCATION 1340 E. Lake Blvd.  
Washoe Valley, Nev. Washoe Valley Nev.  
 2. LOCATION SW 1/4 NW 1/4 Sec. 30 T. 17N N/S R. 20E E Washoe County  
 PERMIT NO. 50-279-09 New Washoe City Subdivision Name  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	18	18
Clay		18	37	19
Gravel		37	43	6
Clay		43	61	18
D.G.	X	61	86	25
Granit, Few Fisures	X	86	170	84

8. WELL CONSTRUCTION  
 Depth Drilled 170 Feet Depth Cased 170 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 Feet To 60 Feet  
12 1/4 Inches  
 From 60 Feet To 170 Feet  
8 3/4 Inches  
 From 170 Feet To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		0.188	0	170

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 3/32 X 3"  
 From 130 feet to 150 feet  
 From 70 feet to 90 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 51 ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 51 feet to 170 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Pre-Cambrian Drilling Co. Inc. Contractor  
 Address 794 Foothill Rd. Gardnerville, Contractor  
Nev. 89410  
 Nevada contractor's license number issued by the State Contractor's Board 0030267  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1652  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 10/10/91

Date started 9/9, 1991  
 Date completed 9/13, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2</u>

91 OCT 16 AM 10:03  
 STATE ENGINEERS OFFICE