WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38021
Permit No.
Basin 89

NOTICE OF INTENT No. 19473

1. OWNER Shag + Pat Taynton
MAILING ADDRESS 2950 Eagle St. 3950 King Row Reno NV. 89503
ADDRESS AT WELL LOCATION 2950 Eagle St. East Washo
2. LOCATION ¼ SE ¼ Sec. Sec 31 T 17 N S R 20 E Washo County
PERMIT NO. Issued by Water Resources | Parcel No. 050-401-22 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	45	45
Hard Sandstone		45	90	45
Sandy Clay		90	105	15
Hard Sandstone		105	155	50
D.G. Sand	xxx	155	170	20
DG sand	xxx	175	180	5
Blue Granite		180	185	5
T.D. 185				

Date started 9-20, 1991
Date completed 9-23, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	90	2 Hr

8. WELL CONSTRUCTION
Depth Drilled 185' Feet Depth Cased 185' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	55 Feet
10' Inches	55 Feet	185 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	185

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 3/32
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 185' feet to 50 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. 5 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AHA Pump Co. Contractor
Address 5551 Hy 50 East #3 Carson City Nv. 89701 Contractor
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Bulls
By driller performing actual drilling on site or contractor
Date 9-20-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627