WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38042
Permit No. [illegible]
Basin [illegible]

NOTICE OF INTENT NO. 19481

1. OWNER American Flats Water Co
MAILING ADDRESS NY 50 East
Dayton Nevada
ADDRESS AT WELL LOCATION Mode

2. LOCATION SE ¼ NW ¼ Sec. 7 T. 16 N/S R. 21 E. Storey County
PERMIT NO. 50653 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	10	10
Black & grey		10	60	50
Gravel	x	60	120	60
Gravels	xxx	120	145	25
Hard Black Rock		145	160	15
Gravels	xxx	160	205	45
Gravels	xxx	205	230	25
Gravels w/ Small Clay Seams	xxx	230	245	15
T.D. 245'				

91 DEC 12 AM 11:42
RECEIVED
STATE ENGINEERS OFFICE

Date started 11-18, 1991
Date completed 12-7, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125	100'	6

8. WELL CONSTRUCTION
Depth Drilled 245' Feet Depth Cased 245' Feet

HOLE DIAMETER (BIT SIZE)
14¼ Inches From 0 Feet To 245' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 7/8	17.09	.188	0	245'

Perforations:
Type perforation Mill Slot
Size perforation 3 X 2/32
From 95 feet to 245' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 245' feet

9. WATER LEVEL
Static water level 65' feet below land surface
Artesian flow G.P.M. 125 T P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H&H Pump Co (Contractor)
Address 5551 NY 50 East #3 (Contractor)
Carson City NV. 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts (By driller performing actual drilling on site or contractor)
Date 12-19-91

(Rev. 3-91) Well #7 USE ADDITIONAL SHEETS IF NECESSARY (O)-027