WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 38050
Permit No. 56781
Basin 230

NOTICE OF INTENT NO. 8334

1. OWNER Nye County. ADDRESS AT WELL LOCATION Amargosa Valley
MAILING ADDRESS

2. LOCATION SE ¼ SW ¼ Sec. 2 T. 18 N/S R. 49 E. Nye County
PERMIT NO. 56781 (Issued by Water Resources) | 19-471-04 (Parcel No.) | Little Neveda Subdivision (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam + gravel		0'	10'	10'
cmt sand + gravel		10'	17'	7'
Clay + gravel		17'	68'	51'
cmt sand + gravel		68'	77'	9'
Clay		77'	94'	17'
Calichie	WB	94'	96'	2'
Clay		96'	105'	9'
Calichie	WB	105'	110'	5'
Clay		110'	124'	14'
Calichie	WB	124'	135'	11'
Clay		135'	144'	9'
Calichie	WB	144'	180'	36'
cmt gravel	WB	180'	191'	11'
Clay		191'	230'	39'

RECEIVED
NOV 01 1991
Div. of Water Resources
Branch Office - Las Vegas, Nv

Date started 10-21, 19 91
Date completed 10-23, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 230' Feet Depth Cased 230' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0' Feet	55' Feet
9 7/8 Inches		55' Feet	230' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	230'

Perforations:
Type perforation factory sawcut
Size perforation 18 x 3
From 230' feet to 210' feet
From 190' feet to 150' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 230' feet to 50' feet

9. WATER LEVEL
Static water level 87' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, Nv. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 10-28-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627