


OFFICE USE ONLY
 Log No. 38058
 Permit No. 87
 Basin 87


PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17275

1. OWNER GENTRY SLEEP CENTER ADDRESS AT WELL LOCATION 92.00 S VIRGINIA ST
RENO NV 89511 RENO NV 89511
 MAILING ADDRESS 92.00 S VIRGINIA ST
RENO NV 89511
 2. LOCATION NE 1/4 NE 1/4 Sec 07 T. 18 N. S. R. 20 E. WASHOE County
 PERMIT NO. M/O-450 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG M3

Material	Water Strata	From	To	Thick-ness
ASPHALT CONCRETE	NO	0	0.2'	0.2'
ORANGE-BROWN AGGREGATE BASE (SAND & GRAVEL)	NO	0.2'	1.5'	1.3'
CLAY				
GRAVEL (FILL)	NO	1.5'	6.0'	4.5'
BROWN TO GREEN CLAYEY SAND	YES	6.0'	15.0'	9.0'

8. WELL CONSTRUCTION
 Depth Drilled 15 Feet Depth Cased 15 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 15 Feet
 Inches Feet
 Inches Feet
 Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>	<u>PVC</u>	<u>SCHED. 40</u>	<u>0</u>	<u>15</u>

Perforations:
 Type perforation SLOTTED
 Size perforation 0.720"
 From 5 feet to 15 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 2 feet
 Placement Method: Pumped Poured BENTONITE PLUG 7.0-3.5'
 Gravel Packed: Yes No #3 SAND
 From 3.5 feet to 15 feet

9. WATER LEVEL
 Static water level 6.5 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature 60.0 °F Quality CLEAR TO EQUIPMENT LAUNCH

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Paul Anderson Contractor
 Address 1635 Belford RD
RENO NV 89509
 Nevada contractor's license number issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1028
 Signed Paul Anderson
 By driller performing actual drilling on site or contractor
 Date 3/21/92

Date started 1-25 1992
 Date completed 1-25 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

'92 MAR 24 AM 1:13
 STATE ENGINEER'S OFFICE