WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38078
Permit No.
Basin 89

NOTICE OF INTENT NO. 17707

1. OWNER Bailey Const
MAILING ADDRESS 990 La Rue Ave Reno NV.
ADDRESS AT WELL LOCATION 1145 Brenda WAY

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 17 N/S R. 20 E/W New Washoe County
PERMIT NO. Issued by Water Resources
050-251-08 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	10	10
Firm D.G.		10	85	75
Hard broken Granite		85	105	20
D.G. Sands w/ small water	X	105	135	30
Hard Gray Granite		135	220	85
Hard Grey Broken Granite		220	270	50'
Hard Broken Granite w/ water	XX	270	300	30
T.D. 300' Static 80'				

Date started 1/6, 1992
Date completed 1/11, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5-7	150	2

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11¼ Inches		0 Feet	55' Feet
9⅞ Inches		55' Feet	300' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	13.03	.188	0	300'

Perforations:
Type perforation Mill Slot
Size perforation 3½ x 33½
From 120' feet to 148' feet
From 180 feet to 300' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 300 feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow G.P.M. 5-7 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Pump Co. Contractor
Address 5551 Hy 50 E. #3 Contractor
Carson City NV 89701
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed Joe Butts
By driller performing actual drilling on site or contractor
Date 1/13/92

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627