

OFFICE USE ONLY
 Log No. 38091
 Permit No. _____
 Basin 102



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19253

1. OWNER BILL BETZ ADDRESS AT WELL LOCATION 2870 Springfield Silver Springs Nev 89429
 MAILING ADDRESS 2994 Springfield Silver Springs Nev 89429
 2. LOCATION S E 1/4 SE 1/4 Sec 18 T 17 N R 25 E Lyon County
 PERMIT NO. #32 NPW 19-292-14 Parcel No. _____ Subdivision Name Sage Brush #1
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|----------------------------------|--------------|------|-----|-----------|
| Fine to Coarse Sand | | 0 | 10 | 10 |
| Brown Clay + Sand | | 10 | 28 | 18 |
| Black Coarse Sand | | 28 | 48 | 20 |
| Black Clay + Sand | | 48 | 50 | 2 |
| Fine Brown Sand | | 50 | 76 | 26 |
| Fine + Coarse Sand | | 76 | 94 | 18 |
| Black Coarse Sand and Black Clay | | 94 | 116 | 22 |
| Coarse Sand + Gravel | X | 116 | 149 | 33 |

8. WELL CONSTRUCTION
 Depth Drilled 149 Feet Depth Cased 150 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 149 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u> | <u>12.92</u> | <u>1.188</u> | <u>71</u> | <u>149</u> |

Perforations:
 Type perforation Sawed
 Size perforation 1 1/2" x 3" 6 ROWS
 From 129 feet to 149 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 149 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N By Bee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Lee Ogden
 By driller performing actual drilling on site or contractor
 Date 2-21-92

Date started FEB 10 1992
 Date completed FEB 13 1992

7. WELL TEST DATA

| TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | | | |
|---|-----------|-------------------------------|----------------|
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| <u>Bailer</u> | <u>40</u> | <u>5</u> | <u>1/2 HRS</u> |