WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38092
Permit No.
Basin 102

NOTICE OF INTENT NO. 17352

1. OWNER Curtis Davis
MAILING ADDRESS 11401 Rocky Mt. Reno Nev 89506
ADDRESS AT WELL LOCATION 1650 East Prime Silver Springs Nev 89429

2. LOCATION S½ ¼ NE ¼ Sec. 30 T. 19 N/S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) APN 19-444-06 (Parcel No.) River Side Sub #1 Lot #60 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand		0	2	2
Hard Pan-Sand		2	5	3
Coarse Sand		5	10	5
Brown Clay		10	12	2
Coarse Sand		12	18	6
Brown Clay		18	25	7
Brown Clay + Coarse Sand		25	30	5
Coarse Sand + Small Gravel		30	52	22
Fine to Coarse Sand		52	66	14
Bluish Gray Clay + Sand		66	123	57
Coarse Sand + Gravel (Bluish)		123	145	22
Coarse Sand		145	148	3
Coarse Sand + Brown Clay		148	152	4
Coarse Sand + Bluish Clay		152	158	6
Coarse Sand		158	164	6
Bluish Clay + Fine Sand		164	167	3
Coarse Sand		167	170	3
Coarse Sand + Gravel - Few Rock		170	199'3"	29'3"

Date started 1-27, 1992
Date completed 1-29, 1992

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	30	4	½ Hr.

8. WELL CONSTRUCTION
Depth Drilled 199'3" Feet Depth Cased 200'3" Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 3/8 Inches		0 Feet	199'3" Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	199'3"

Perforations:
Type perforation Factory Sawed
Size perforation 18 x 3" 6 Rows
From 199'3" feet to 199'3" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 199'3" feet

9. WATER LEVEL
Static water level 41' feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ogden Bros Drilling (Contractor)
Address 162 N. Byrne Lane (Contractor)
Yerington Nev 89447
Nevada contractor's license number issued by the State Contractor's Board 15646
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed Jerry Ogden (By driller performing actual drilling on site or contractor)
Date 2-22-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627