


OFFICE USE ONLY  
 Log No. 38093  
 Permit No. \_\_\_\_\_  
 Basin 103



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19385  
9345 Santa Fe Trail  
Silver Springs NEV 89427

1. OWNER Victor Borg ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6 Raglan \_\_\_\_\_  
Carson City Nev 89701 \_\_\_\_\_  
 2. LOCATION NW 1/4 SE 1/4 Sec. 3 T. 12 N. R. 03 E. 40N County \_\_\_\_\_  
 PERMIT NO. 15-411-78 Parcel No. \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_ Subdivision Name #105265 Document

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Clay		0	3	3
Coarse Sand		3	5	2
Coarse Sand & Clay		5	9	4
Coarse Sand & Gravel with Clay		9	48	39
Coarse Sand, Gravel & Rock		48	54	6
Coarse Sand, Gravel & Clay		54	62	8
Coarse Sand, Gravel, Rock		62	70	8
Coarse Sand, Gravel & Clay		70	76	6
Coarse Sand, Gravel & Rock		76	82	6
Coarse Sand, Gravel & Clay		82	98	16
Coarse Sand, Gravel & Hard Clay		98	105	7
Coarse Sand, Gravel & Rock		105	115	10
Coarse Sand, Gravel & Rock		115	119	4
Coarse Sand, Gravel, Rock & Clay		119	132	13
Coarse Sand, Gravel, Rock & Clay Strata	X	132	148	16
Coarse Sand Gravel and Clay		148	157	9
Coarse Sand Gravel Rock & Clay Strata	X	157	179	22

8. WELL CONSTRUCTION  
 Depth Drilled 179 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
179 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.92</u>	<u>1/8</u>	<u>+1</u>	<u>179</u>

Perforations:  
 Type perforation Sawed  
 Size perforation 1/2 x 3" 6 Rows  
 From 157 feet to 179 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 179 feet

9. WATER LEVEL  
 Static water level 29 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ogden Bros Drilling Contractor  
 Address 162 N Bybee Lane Contractor  
Yerington NEV 89447  
 Nevada contractor's license number issued by the State Contractor's Board 15646  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634  
 Signed Ray Nelson  
 By driller performing actual drilling on site or contractor  
 Date 3-2-92

Date started 2- 24 1992  
 Date completed 2- 28 1992

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Bailer</u>	<u>28</u>	<u>20</u>	<u>1/2 Hr</u>