WHITE—DIVISION OF WATER RESOURCES PZ-92-3
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

DUAL COMPLETION
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38717
Permit No.
Basin 51

NOTICE OF INTENT NO. 19385

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NE ¼ Sec. 30 T. 36 N/S R. 50 E. EUREKA County
PERMIT NO. M/0441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL	0	0	55	55
WEATHERED DIONTIE	0	55	100	45
GRAY-GREEN DIONTIE	200	100	705	605

'92 APR 14 A9:51
STATE ENGINEER'S OFFICE

Date started MARCH 9, 19 92
Date completed MARCH 13, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		

8. WELL CONSTRUCTION
Depth Drilled 705 Feet Depth Cased 705 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.5 Inches		0 Feet	65 Feet
6.5 Inches		65 Feet	705 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.00	38	.500	0	65
1.25	2.25	.140	0	705
1.25	2.25	.140	0	350

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From 1. 560 feet to 705 feet
From 2. 250 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 65'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 1. 705-540 feet to 2. 350-230 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 50 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 W 1500 S SLC, UT 84104 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed [signature] (By driller performing actual drilling on site or contractor)
Date MARCH 15, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627