WHITE—DIVISION OF WATER RESOURCES PZ-92-2
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
DUAL COMPLETION

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38121
Permit No.
Basin 51

NOTICE OF INTENT NO. 19387

1. OWNER BARRICK GOLDSTRIKE
MAILING ADDRESS P.O. BOX 29
ELKO, NV 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 36 N/S X R. 50 E. EUREKA County
PERMIT NO. M/0441 (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND, GRAVEL, BOULDER	0	0	75	75
WEATHERED DIONITE	0	75	125	50
GRAY, DARK GRAY, GREEN		125	835	710
DIONITE				

'92 APR 14 A9:51
STATE ENGINEER

Date started MARCH 4, 19 92
Date completed MARCH 9, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		1 LOYAL

8. WELL CONSTRUCTION
Depth Drilled 835 Feet Depth Cased 835 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	85	Feet
6.50	Inches	85	Feet	835	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7.00	38	.500	0	85
1.25	2.25	.140	0	835
1.25	2.25	.140	0	484

Perforations:
Type perforation DRILLED
Size perforation 1/8"
From 1. 735 feet to 835 feet
From 2. 400 feet to 484 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 85'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1. 835-720 feet to 2. 500-385 feet

9. WATER LEVEL
Static water level 351 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 58 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 W 1500 S SLC, UT 84104 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410
Signed [signature] (By driller performing actual drilling on site or contractor)
Date MARCH 9, 1992

(Rev. 3-91) **USE ADDITIONAL SHEETS IF NECESSARY** (O)-627