WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38137
Permit No.
Basin 71

NOTICE OF INTENT NO. 20192

1. OWNER Manuel Esquivel
MAILING ADDRESS Winnemucca, Nevada 89446
ADDRESS AT WELL LOCATION Grass Valley Rd. Winnemucca, Nevada 89446

2. LOCATION NE ¼ SW ¼ Sec. 24 T. 35 X N/S R. 37 E. Humboldt County
PERMIT NO. – (Issued by Water Resources) Parcel No. C Subdivision Name –

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	20	20
Gravel & Clay		20	40	20
Gravel & Light Clay		40	60	20
Gravel	x	60	80	20
Gravel	x	80	100	20
Gravel	x	100	120	20
Gravel	x	120	140	20

'92 MAR 12 A11:02 STATE ENGINEER'S OFFICE

Date started March 5, 19 92
Date completed March 6, 19 92

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25-30	air on rig	5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
97/8 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	100

Perforations:
Type perforation Mill
Size perforation 1/8 X 2
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow – G.P.M. – P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling and Pump Co. (Contractor)
Address P.O.BOX 590 (Contractor)
Winnemucca, Nevada 89446-0590
Nevada contractor's license number 015234 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1195-T
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3 91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627