WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 38738
Permit No.
Basin 76

NOTICE OF INTENT NO. 19520

1. OWNER Dennis Pennington
MAILING ADDRESS 865 Woodchuch
Fernley, Nevada 89408

ADDRESS AT WELL LOCATION 865 Woodchuch
Fernley Nevada 89408

2. LOCATION SE ¼ SE ¼ Sec. 10 T 20 N/S R 24 E Lyon County
PERMIT NO. (Issued by Water Resources) 20-151-09 (Parcel No.) G-Dodd Parcels (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Clay | | 68 | 105 | 37 |
| Gray Sandy Clay | | 105 | 113 | 8 |
| Brown Sandy Clay | | 113 | 118 | 5 |
| Black Clay | | 118 | 136 | 18 |
| Brown Sandy Clay | | 136 | 138 | 2 |
| Brown & Black Coarse Sand | | 138 | 155 | 17 |

Date started March 10, 19 92
Date completed March 10, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6 Inches | | 68 Feet | 154 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5 | 10.79 | .188 | 60 | 154 |
| | | | | |
| | | | | |

Perforations:
Type perforation Torch Cut
Size perforation 1/8"
From 148 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 57 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nevada 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date March 12, 1992

'92 MAR 18 AM 8:36 STATE ENGINEER

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627