

OFFICE USE ONLY
 Log No. 38143
 Permit No. _____
 Basin 83

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18831

1. OWNER RON FRANKLIN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2346 Oppio Street _____
Sparks, NV 89431 _____
2203 Cartwright _____
Virginia City, NV _____
 2. LOCATION SW 1/4 SW 1/4 Sec. 31 T. 18N N/S R. 21 E. Storey County
 PERMIT NO. 03-015-01 _____
 Issued by Water Resources Parcel No. _____
 Subdivision Name Virginia City Highlands

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Gray volcanic roack		1	129	128
Soft gray clay		129	140	11
Gray volcanic rock		140	152	12
FRacture (app 8 GPM)	X	152	155	3
Purple volcanic rock		155	189	34
Fracture	X	189	190	2
Purple Volcanic rock		190	218	28
Fracture	X	218	221	3
Purple volcanic rock		221	238	17
XXXXXXX Fracture	X	238	240	2
Purple volcanic rock		240	245	5

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 245 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	245

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 180 feet to 200 feet
 From 220 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 245 feet

9. WATER LEVEL
 Static water level 146 feet below land surface
 Artesian flow 100 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 908
 Signed Jay C. Hedman Driller performing actual drilling on site or contractor
 Date March 9, 1992

Date started 2-28-92, 19____
 Date completed 3-2-92, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

92 MAR 11 AM 11:30
 STATE ENGINEERS OFFICE