

OFFICE USE ONLY
 Log No. **38147**
 Permit No. _____
 Basin **83**
 NOTICE OF INTENT NO. **18280**

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Granite Construction ADDRESS AT WELL LOCATION Lockwood Pit
 MAILING ADDRESS P. O. Box 2087
Sparks, Nv 89432
 2. LOCATION SE 1/4 NW 1/4 Sec 17 T. 19 N/S R. 21 E Washoe County
 PERMIT NO. 56332 84-070-10 -
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
There was open hole <u>6" casing</u> from 220 ft to 236 ft				
Red volcanic rock		236	238	2
Pinkish red - red & black volcanic rock		238	260	22
Red black brown volcanic gravels red brown tan grey white sands fine		260	325	65
Red & black & white volcanic rock		325	330	5
Red volcanic rock		330	340	10
T.D. 341 ft				

Repeating of log # 22426
QA by log # 41738/

8. WELL CONSTRUCTION
 Depth Drilled 341 Feet Depth Cased 341 Feet
 HOLE DIAMETER (BIT SIZE)
 From 236 Feet To 341 Feet
6 1/8 Inches
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.62	.188	201	341

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 260 feet to 280 feet
 From 320 feet to 341 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal refer to original log
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level flowing _____ feet below land surface
 Artesian flow 2 G.P.M. _____ P.S.I.
 Water temperature warm °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service Inc.
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1804
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or Contractor
 Date Roger M. Thrall 3/3/92

Date started 2/28/92, 19_____
 Date completed 3/2/92, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump **WATER DIVISION**

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20+</u>	<u>25.6</u>	<u>3</u>
	<u>27.4</u>	<u>26</u>