WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38148
Permit No.
Basin 83

NOTICE OF INTENT NO. 20980

1. OWNER Asmera Minerals
MAILING ADDRESS 6121 Lakeside Drive Ste.B
Reno, Nevada 89511-8502

ADDRESS AT WELL LOCATION NONE

2. LOCATION NE ¼ NW ¼ Sec. 5 T 19 N/S R 22 E MDM MDB & M Storey County

PERMIT NO. 57120 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine Sand		0	37	37
Red Volcanic Rock W/Quartz		37	160	123
Fractured Red Volc.	X	160	172	12
Red Volcanic Rock		172	205	33
First Water	105			

92 MAR 27 P1:33 STATE ENGINEER

Date started March 15, 1992
Date completed March 18, 1992

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Airlift	80		3 hours
Pump test	105	93'.4"	24 hours

8. WELL CONSTRUCTION
Depth Drilled 205 Feet Depth Cased 205 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 Inches		0 Feet	50 Feet
10 Inches		50 Feet	205 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	205

Perforations:
Type perforation Factory Slot
Size perforation 1/8th x 3 inch
From 128 feet to 188 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50 ft.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet feet to 205' feet

9. WATER LEVEL
Static water level 80 feet feet below land surface
Artesian flow 0 G.P.M. P.S.I.
Water temperature 50°+ °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Drift Exploration (Contractor)
Address (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #22214
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 891
Signed (By driller performing actual drilling on site or contractor)
Date 3/19/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627