WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38152
Permit No.
Basin 87

NOTICE OF INTENT NO. 18539

1. OWNER John Kaye
MAILING ADDRESS 3880 Fairview Rd.
Reno, NV 89511

ADDRESS AT WELL LOCATION 3880 Fairview Rd.
Reno, NV 89511

2. LOCATION NW ¼ SW ¼ Sec. 12 T. 18N N/S R. 19 E. Washoe County

PERMIT NO. (Issued by Water Resources) | Parcel No. 40-692-11 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		1	2	2
Silty Sand		2	14	12
Clay & Sand		14	31	17
Sand & Gravel		31	64	33
Red Clay		64	74	10
Brown Clay		74	110	36
Hard Grey rock		110	145	35
Fractured grey rock		145	168	23
Grey rock	x	168	240	72
Hard grey rock		240	261	21
Fractured grey rock	x	261	274	13
Black Basalt w/ quartz	x	274	290	16
Very hard black basalt	x	290	335	45
Black Basalt w/yellow clay		335	350	15

'92 MAR 27 P1:35
STATE ENGINEER

Date started 3-20, 1992
Date completed 3-23, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	190	1 hour

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	64 Feet
8 Inches		64 Feet	350 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	0	350

Perforations:
Type perforation Factory
Size perforation .070 x 3
From 280 feet to 300 feet
From 320 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P.O. Box 888 (Contractor)
Fallon, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-23-'92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627