WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 38175
Permit No.
Basin 101

NOTICE OF INTENT NO. 19525

1. OWNER Dividend Construction
MAILING ADDRESS P.O. Box 1915
Fallon, Nevada 89407

ADDRESS AT WELL LOCATION 4160 Bottom Road
Fallon, Nv. 89406

2. LOCATION NE ¼ NE ¼ Sec 33 T 19 N/S R 28 E Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. 3 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Topsoil | | 0 | 11 | 11 |
| Coarse Sand | | 11 | 23 | 12 |
| Brown Clay | | 23 | 31 | 8 |
| Brown Coarse SAnd | | 31 | 42 | 11 |
| Green Sand | | 42 | 44 | 2 |
| Green & Black Coarse Sand | | 44 | 46 | 2 |
| Black Clay | | 46 | 49 | 3 |
| Black & Green Coarse Sand | | 49 | 76 | 27 |
| Brown Clay | | 76 | 81 | 5 |
| Black & Brown Coarse Sand | X | 81 | 90 | 9 |

'92 APR 21 AM 11:13 STATE ENGINEER

Date started March 22, 19 92
Date completed March 22, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 90 Feet Depth Cased 90 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 90 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6-5/8 | 12.92 | .188 | 0 | 90 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 86 feet to 89 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 90 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NEV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Douglas Parsons (By driller performing actual drilling on site or contractor)
Date April 17, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627