

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20089

1. OWNER Mark Williams ADDRESS AT WELL LOCATION 4980 Dry Gulch Rd
 MAILING ADDRESS P. O. Box 116 Virginia City, Nv 89440 Lot 498
 2. LOCATION SW 1/4 NE 1/4 Sec 8 T 17 N/S R 21 E Storey County Highland Ranches
 PERMIT NO. 03-412-03 Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	1	1
Tan clay & volcanic rock		1	15	14
Volcanic rock & sands		15	55	40
Little tan clay decomposed multi-colored volcanic rock & multi sands		55	65	10
Mostly green some purple white specs		65	90	25
Green white specs		90	101	11
Mostly bluish purple some green white specs		101	130	29
Purple white specs		130	145	15
Purple white specs & bluish purple white specs		145	170	25
Purple & green white specs		170	230	60
Green lite green white specs		230	240	10

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 50 Feet
 10 5/8 Inches
 From 50 Feet To 240 Feet
 8 1/2 Inches
 From _____ Feet To _____ Feet
 _____ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	240

Perforations: factory
 Type perforation _____
 Size perforation 3/32 X 3
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 178 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc
 Address 625 Spice Islands Dr Suite L Sparks, Nv 89431
 Nevada contractor's license number 15291 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1804 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall By driller performing actual drilling on site or contractor
 Date 7/8/92

Date started 7/6/92, 19____
 Date completed 7/7/92, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>