

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF PERMIT NO. 2866

1. OWNER GARY WILCOX ADDRESS AT WELL LOCATION same
 MAILING ADDRESS 183 Gonscho Drive
 2. LOCATION NE 1/4 SE 1/4 Sec 7 T 17 N R 19 E Washoe County
 PERMIT NO. 050-111-02 Parcel No. 20 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	15	
Boulders		15	90	
CLAY		90	148	
ROCK + BROWN CLAY		148	153	

'92 AUG 13 AM 10:08
 RECEIVED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 153 Feet Depth Cased 153 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" To 153
 Inches Feet Feet
 Casing Schedule

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	12.92	1.88	0	65
			113	133

 Perforations:
 Type perforation Factory + mills rite
 Size perforation 7/8"
 From 65 feet to 153 feet
 From 133 feet to 153 feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 ft Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 153 feet
 9. WATER LEVEL
 Static water level 25 feet below land surface
 Artesian flow 30 G.P.M. P.S.I.
 Water temperature 59 °F Quality

Date started June 22 - 1992
 Date completed July 6 - 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 hrs

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Steve McKay Contractor
 Address 2290 Pioneer Drive Contractor
Reno Nevada 89509
 Nevada contractor's license number 14170
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 786
 Division of Water Resources, the on-site driller.
 Signed Steve McKay
 By driller performing actual drilling on site or contractor
 Date 7/7/92

BOB MILLER
Governor

STATE OF NEVADA

38252
PETER G. MORROS
Director

R. MICHAEL TURNIPSEED, P.E.
State Engineer



DEPARTMENT OF CONSERVATION AND NATURAL RESOURCES
DIVISION OF WATER RESOURCES

Capitol Complex
123 W. Nye Lane
Carson City, Nevada 89710
(702) 687-4380

R-158

June 30, 1992

Gary Wilcox
Wilcox Construction
4765 Giles Way
Carson City, NV 89704

RE: Request to waive 100 foot seal requirement for 183 Concho Drive, Pleasant Valley, Nevada Local No = NE SE Section 7, 17N 19E., MDB&M

Dear Mr. Wilcox:

As provided in Section 534.450 of the Regulation for Water Well and Related Drilling as adopted under Chapter 534 of the Nevada Administrative Code, and for good cause shown, authorization is herewith granted to complete the subject well as described below:

This letter waives NAC 534.390.1(b) which requires a 100 foot seal if within $\frac{1}{4}$ mile of any surface flow. The seal is to be from the top of of the perforations to ground level, but not less than 50 feet.

Full compliance with the remainder of the statute and regulation is required. Please include as accurate a description as possible of the location of each well on the completion reports. It is expressly understood this authorization does not relieve the operator of the permitting requirements of other state, federal and local agencies.

If any questions arise please contact this office at 702-687-4380.

Sincerely,

Handwritten signature of Robert K. Martinez.
Robert K. Martinez
Hydraulic Engineer II

RKM/jjs