

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19747  
1385 Glenda

1. OWNER D. Bailey ADDRESS AT WELL LOCATION Way E Washo  
 MAILING ADDRESS 290 La Rue Ave Reno NV.  
 2. LOCATION NE 1/4 HW 1/4 Sec. 31 T. 17 S. R. 20 E. Washo. County  
 PERMIT NO. 50-367-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Blow Sand		0	25	25
Coarse sand		25	40	15
Brown Clay		40	55	15
Coarse D.G. Sands		55	70	15
D.G. Boulders		70	95	25
D.G. Sands		95	115	20
Brown Coarse Sand		115	135	20
Brown Clay		135	140	5
D.G. Sand	xx1	140	160	20

T.D. 160'  
 Static 60'  
 C.P.M 7-8

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>12 1/4</u>	0	55	55	55
<u>9 7/8</u>	55	160	160	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:  
 Type perforation Mill slot  
 Size perforation 3/2 x 3/32

From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 140 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 55  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 160 feet

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 7-8 P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge. A & H PUMP CO.  
 Name 5551 Hwy. 50 East #3  
 Address Person City Nevada 89711  
 Phone 702-293-1800  
 Contractor \_\_\_\_\_

Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed Joe Butts  
 By driller performing actual drilling on site or contractor  
 Date 7/29/92

Date started 7-27, 1992  
 Date completed 7-29, 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>7-8</u>	<u>50'</u>	<u>2 1/2</u>