

OFFICE USE ONLY  
Log No. 38265  
Permit No. 19744  
Basin I

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19744

1. OWNER Dale B Arcum ADDRESS AT WELL LOCATION 3075 Lakeshore Blvd. E. Washo.  
MAILING ADDRESS 3075 Lakeshore Blvd. E. Washo. Carson City NV. 89794  
2. LOCATION NW 1/4 NE 1/4 Sec. 6 T. 14 S. R. 20 E. Washo. County  
PERMIT NO. 050-340-05 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Blow Sand</u>		<u>0</u>	<u>5</u>	<u>5'</u>
<u>Course Sandstone</u>		<u>5</u>	<u>35</u>	<u>30'</u>
<u>Sand w/ Grey Clay seams</u>		<u>35</u>	<u>90</u>	<u>45'</u>
<u>Silt Sand</u>		<u>90</u>	<u>128</u>	<u>38'</u>
<u>DG. Sands</u>		<u>128</u>	<u>140</u>	<u>12'</u>

8. WELL CONSTRUCTION  
Depth Drilled 140' Feet Depth Cased 140' Feet  
HOLE DIAMETER (BIT SIZE)  
From 11 3/4 Inches 0 Feet 55' Feet  
To 9 3/4 Inches 55 Feet 100' Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
Type perforation Mill slot  
Size perforation 3 1/2 x 3/32  
From 120' feet to 140' feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 55'  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 55' feet to 140' feet

9. WATER LEVEL  
Static water level 10 feet below land surface  
Artesian flow 25' G.P.M. 25' P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A & H PUMP CO.  
5551 Hwy. 50 East #3  
Carson City, Nevada 89706  
Address 70459 - 883-4000

Date started 7-12 1992  
Date completed 7-13 1992

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>257</u>	<u>20</u>	<u>2 1/2</u>

Nevada contractor's license number issued by the State Contractor's Board 31839  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
Signed Joe Bulbs  
By driller performing actual drilling on site or contractor  
Date 7/28/92

'92 AUG 13 P 1:44  
STATE ENGINEERS OFFICE